

Cement Test Certificate

Final

Product Certified: Type SL Shrinkage Limited Cement
Test Certificate Number: 250096
Customer: Adbri Cement, Port Kembla Plant, NSW
Sample Code: B0b3a9a
Sample Date: 9/01/2025

| Nominal Blend | Requirements | Result |
|---|--------------|--------|
| Clinker | | >85 % |
| Ground Granulated Iron Blast-Furnace Slag | | Nil |
| Mineral Addition | Max 7.5 % | <7.5 % |
| Calcium Sulphate | | 4-8 % |
| Minor Additional Constituents | Max 5 % | <5 % |

| Reportable Property | Test Method | Requirements of AS3972 | Result |
|---|---------------|------------------------|-------------|
| 3 Day Strength | AS/NZS2350.11 | N/R | 33.8 MPa |
| 7 Day Strength | AS/NZS2350.11 | Min 35.0 MPa | 48.7 MPa |
| 28 Day Strength | AS/NZS2350.11 | Min 45.0 MPa | 62.7 MPa |
| Initial Set Time | AS/NZS2350.4 | Min 45 min | 150 min |
| Final Set Time | AS/NZS2350.4 | Max 600 min | 195 min |
| Soundness | AS/NZS2350.5 | Max 5 mm | 1 mm |
| Sulfuric Anhydride content (SO ₃) | AS2350.2 | Max 3.5 % | 3.0 % |
| Chloride Ion | BH-TM-0507 | Max 0.10 % | 0.015 % |
| Shrinkage 28 Days | AS2350.13 | Max 750 µstrain | 600 µstrain |

Other Properties

| | | | |
|--------------------------------|--------------|-----|------------------------|
| SiO ₂ | AS2350.2 | N/R | 19.0 % |
| Al ₂ O ₃ | AS2350.2 | N/R | 5.1 % |
| Fe ₂ O ₃ | AS2350.2 | N/R | 3.1 % |
| CaO | AS2350.2 | N/R | 63.4 % |
| MgO | AS2350.2 | N/R | 1.4 % |
| Na ₂ O Equivalent | AS2350.2 | N/R | 0.5 % |
| Loss on Ignition | AS2350.2 | N/R | 4.3 % |
| Fineness Index | AS/NZS2350.8 | N/R | 350 m ² /kg |
| Normal Consistency | AS/NZS2350.3 | N/R | 27.6 % |

This document shall not be reproduced except in full.

REMARKS


These test result apply specifically to the sample as received at the Adbri Cement Birkenhead Laboratory (Accreditation number: 252), 62 Elder Rd Birkenhead SA 5015.

This despatch grab sample complies to the requirements of AS3972:2010, Type SL Cement.

N/R = No Requirement



Accredited for compliance with ISO/IEC
17025 - Testing.



Approved Signatory

M. Wythe

Issue Date: 10/03/2025